

Sprinkler or Kitchen Hood Suppression System Requirements for Shenandoah County



Sprinkler Systems

All automatic sprinkler systems, which include relocating or adding more than five heads per fire area, require two sets of plans, calculations, and specifications sealed by a Virginia *certified design professional*, this includes NFPA 13, 13D and 13R systems.

Design, installation, inspections, and testing shall be performed as set forth in the applicable section of the current edition of the Virginia Uniform Statewide Building Code, the NFPA and the International Building Code.

Fees: Please refer to our fee schedule for all Sprinkler permit fees and state levy.

Kitchen Hood Systems

All Commercial Kitchen Hood Systems require a permit. This applies to both new systems and relocation of suppression heads. Two sets of drawings are required for all applications.

Fees: Please refer to our fee schedule for Hood System permit fees and state levy. In addition to the suppression permit a separate permit and fee is required for the hood installation.

Inspections must be scheduled 24 hours in advance and a representative must be on site to perform the required tests. Equipment necessary for the inspection shall be provided by the contractor.

If you have any questions, please call our office at (540) 459-6185.